

**NOBLE DENTON MARINE SERVICES**

**CSL ROUGH CRANE REPLACEMENT**

# **Examination of Final Configuration of Crane Adaptor Bolting and Flange**

**Centrica Storage Limited**

**Report No.:** 10016304\106\04\001TN, Rev. 0

**Date:** April 2017

## Table of contents

1	INTRODUCTION.....	1
2	STRUCTURAL ARRANGEMENT.....	1
3	CRANE LOADING .....	5
4	BOLT LOADING .....	5
5	STRESSES IN BOLTING .....	8
6	BOLTING FLANGE .....	11
7	FATIGUE CHECKS .....	13
8	CONCLUSIONS .....	17
9	REFERENCES .....	18

## About DNV GL

Driven by our purpose of safeguarding life, property and the environment, DNV GL enables organizations to advance the safety and sustainability of their business. We provide classification and technical assurance along with software and independent expert advisory services to the maritime, oil and gas, and energy industries. We also provide certification services to customers across a wide range of industries. Operating in more than 100 countries, our 16,000 professionals are dedicated to helping our customers make the world safer, smarter and greener.

Project name:	CSL Rough Crane Replacement	DNV GL - Oil & Gas
Report title:	Examination of Final Configuration of Crane Adaptor Bolting and Flange	Noble Denton marine services 4 <sup>th</sup> Floor
Customer:	Centrica Storage Limited	Vivo Building
Contact person:	Ben Roebuck	30 Stamford Street
Date of issue:	April 2017	London
Project No.:	10016304	SE1 9LQ
Organisation unit:	OBGGB546 SIM & Structures	Tel: +44 20 3 816 4000
Report No.:	10016304\106\04\001TN, Rev. O	

Task and objective:

Assessment of ability of crane pedestal adaptor bolting and bolting flange to resist operating and accidental pedestal loads.

Prepared by:




Nigel Sims  
Asset Leader

Verified by:



Yang Guo  
Senior Engineer

Approved by:



Dr Philip Wicks  
Manager, SIM & Structures Unit

[Fullname]  
[title]

[Fullname]  
[title]

[Fullname]  
[title]

[Fullname]  
[title]

- Unrestricted distribution (internal and external)    Keywords:
- Unrestricted distribution within DNV GL                    [Keywords]
- No distribution (confidential)
- Secret

Copyright © DNV GL 2015. All rights reserved. This Report is protected by copyright and may not be reproduced in whole or in part by any means without the approval in writing of DNV GL. No Person, other than the Customer for whom it has been prepared, may place reliance on its contents and no duty of care is assumed by DNV GL toward any Person other than the Customer.

This Report must be read in its entirety and is subject to any assumptions and qualifications expressed therein. Elements of this Report contain detailed technical data which is intended for analysis only by persons possessing requisite expertise in its subject matter. DNV GL and the Horizon Graphic are trademarks of DNV GL AS.

**DNV GL is the trading name of Noble Denton Consultants Ltd, formally trading as GL Noble Denton.**

Registered in England and Wales No. 05513434. Registered Office: 4th Floor, Vivo Building, 30 Stamford Street, London, SE1 9LQ.

© 2015 Noble Denton Consultants Ltd

Rev. No.	Date	Reason for Issue	Prepared by	Verified by	Approved by
0	2017-04-05	First issue	NXS	YG	PJW

## 1 INTRODUCTION

Centrica Storage Limited (CSL) have requested that the bolting arrangement around the crane pedestal adaptor for the crane on their Rough BP and BD platforms be checked under accidental crane loads and under operating crane loads. This Technical Note describes the work done and its conclusions. This Technical Note builds on work reported previously/1/.

Work is under way to replace the cranes on the Rough BP and BD facilities. The cranes entered service in 1982, so have been in service for some 35 years; they are to be replaced with new units of similar capacity in 2017. The cranes are mounted on cylindrical pedestals fitted adjacent to corners of the modules. At the upper end of the cylinder, a tapered adaptor is fitted which incorporates a circular bolting flange onto which the crane is mounted. The same arrangement is used on both the BP and BD cranes.

For the new cranes, it is required that the pedestals and their supporting structure can resist loads transmitted from the cranes under conditions of catastrophic overload in accordance with Appendix D of reference /1/. These represent loads under which crane components will fail, plus an additional safety factor. Under these accidental loads the pedestal must not collapse; the failure loads of components supporting the crane cabin must be higher than the failure loads for the first crane component to fail.

As part of the crane replacements, new secondary adaptors are to be fitted above the existing adaptors and secured to the existing units with bolts. It is important for ease and speed of fitting that the existing bolt holes on the adaptors can be re-used, to avoid reworking of the holes during installation.

The study reported here addressed the adaptor bolting and adaptor bolting flange under the specified accidental and operating crane loads, considering both strength and fatigue. Such bolting is clearly a vital component in the load path.

It is understood that the same structural arrangement and crane will apply to both the BP and BD units; hence the calculations reported here apply to both. Differences in loading history between BP and BD are taken into account in considering fatigue damage from the existing cranes.


The projected life for the platforms is until 2035, i.e. 18 years if crane replacement takes place in 2017.

## 2 STRUCTURAL ARRANGEMENT

The existing adaptor is welded to the top of the cylindrical crane pedestal. It consists of a flat circular flange supported by two conical steel rings. The flange is drilled to take 72 off 1 ½" diameter bolts. An overview of the adaptor is shown in Figure 2-1/3/.

Above the adaptor, a new secondary adaptor is to be fitted and attached via the bolting flange. Loads from the crane will be transmitted through the secondary adaptor and thence via the 72 bolts to the bolting flange of the adaptor. This secondary adaptor is shown in Figure 2-2. The secondary adaptor is to be supplied by the crane manufacturer; its structural performance is not considered here.

The bolt holes in the existing adaptor are 1 9/16" diameter, to take 1 ½" diameter Imperial bolts. The grade of bolts currently fitted is unknown. It is important for ease and speed of fitting that the existing bolt holes on the adaptor can be re-used, to avoid reworking of the holes during installation. Kenz have specified M36 bolts in the existing holes. These will screw into threaded holes in Kenz's new secondary adaptor.



**Figure 2-1 Pedestal adaptor**

Relevant dimensions used in the calculations are sketched in Figure 2-4. Dimensions given in brackets are converted from the inch units on the original drawing (conversion factor 1" = 25.4 mm).

Kenz's new secondary adaptor is shown in their drawing number P337 6131-010 rev C, see Figure 2-2. The M36 stud for attachment of the new secondary adaptor is shown in Figure 2-3.




Figure 2-2 Kenz design for secondary adaptor





Figure 2-3 M36 stud for attachment of new secondary adaptor



**Figure 2-4 Selected relevant dimensions, existing adaptor**

### 3 CRANE LOADING

The crane loadings considered here are:

- Operating loads – maximum loads arising during normal crane operations, provided by Kenz /4/ to CSL as “Fact. Load incl. Ped. SF (Incl. wind)”;
- Accidental loads – loads which the pedestal must resist without failure were provided by Kenz /4/ to CSL as “Minimum Failure Load Client Ped”

The values of these loads are shown in Table 3-1.


**Table 3-1 Crane loading**

<b>Load</b>	<b>Description</b>	<b>Operating loads</b>	<b>Accidental loads</b>
M (kNm)	Bending moment on pedestal	17,677	38,733
Msl (kNm)	Torsional moment on pedestal	1,869	2,000
Fax (kN)	Axial load on pedestal (downwards)	1,594	2,280
Frad (kN)	Shear force radial to pedestal	115	113

### 4 BOLT LOADING

#### 4.1 Calculation of individual bolt loads

Bolt loads were calculated by applying the provided pedestal load values over the full bolt circle. Axial and shear loads were distributed equally across all bolts. The torsional moment (Msl) was taken as resisted equally on all bolts, via shear in the bolts acting on the bolt pitch circle. The bending moment was distributed to give a linear distribution, so that force carried by a bolt was proportional to its lever arm from the pedestal centreline as sketched in Figure 4-1.



**Figure 4-1 Calculation of bolt load due to moment**

All load components were taken as acting simultaneously, with the axial load acting downwards (i.e. producing a compressive load, thus tending to reduce the tension in the bolts). Kenz confirmed /5/ that the moment and axial force in the accidental loading occur together. They also noted that “The axial force  $F_{ax}$  is caused by the rope being pulled under these conditions (for instance entanglement of the hoisting hook at the support vessel while support vessel shifts away”;

Note that:

- The pedestal failure loads given by Kenz are understood to already include a pedestal factor of 1.3 /11/.
- The radial forces  $F_{rad}$  as supplied by Kenz were taken as acting at the level of the bolting ring - any additional offset would increase the moment on the ring.

On this basis, the individual bolt loads were calculated as shown in Table 4-1.

**Table 4-1 Calculated loads per bolt**


	<b>Operating loads</b>	<b>Accidental loads</b>
Axial load/bolt (kN)	322.0	722.3
Shear load/bolt (kN)	19.8	21.1

## 4.2 Stiffness analysis of the joint

To assess the possibility of prying action, the combined joint was modelled in finite elements. The model is shown in Figure 4-2. This model represented the lower flange of the Kenz adaptor plus the existing flange; the two were connected by a simple representation of the bolt, the model covering one half bolt spacing. The mating faces of the lower and upper flanges were coupled vertically; these couplings were



progressively released to simulate separation under load, as noted below. Vertical coupling was also used to connect the bolt head and the lower flange.



**Figure 4-2 Finite element (FE) model**


The bolt was pretensioned using temperature loads, thermally shrinking the bolt material passing through the lower flange to produce an axial bolt stress. The pretension applied corresponded to a bolt pretensioned to 70% of the yield stress of grade 10.9 material; 2.23.8 of reference /6/ specifies this as the minimum pretension for joints subjected to fluctuating or reversal of loads. Minimum pretension will allow maximum separation in the joint, should that occur.

Axial load was applied to the pedestal body, at the lower end of the model. The upper flange was simply supported where the Kenz adaptor steelwork is attached (see Figure 4-2 and Figure 2-2). A set of cases were considered as summarised in Table 4-2 below (note that these are the loads acting on the model, i.e. on one half of one bolt). Iterative analyses were used, releasing the coupling between lower and upper flanges in areas of tension normal to the mating faces to simulate separation of the flanges.

**Table 4-2 Summary of FE runs**

	External load (kN)	Axial load in bolt (N)
Clampup only	0	514.7
30kN	30	515.9
90kN	90	525.1
operating	161	559.0
accidental	361.15	687.5

Bolt loads from these runs are plotted against applied load in Figure 4-3; these are the loads on a single bolt spacing. It can be seen that the bolt load increases as the extent of flange separation increases.



**Figure 4-3 Axial bolt load vs applied external load**

## 5 STRESSES IN BOLTING

### 5.1 Axial stresses

M36x4 bolts have been specified for the joint by Kenz/7/. These bolts have a stress area of 817 mm<sup>2</sup>. With this cross-section area, the nominal stresses are shown in Table 5-1

**Table 5-1 Calculated bolt stresses**

	Operating loads	Accidental loads
Axial stress (MPa)	394	884
Nominal shear stress (MPa)	24	26

CSL intend the use of RotaBolts in these locations; such bolts include a mechanism for checking the applied axial tension in the bolts. A small hole is drilled along the bolts to incorporate the mechanism, giving a small reduction in cross-section area of the order of 3.8%. Such holes would increase the stress values to those shown in Table 5-2.

**Table 5-2 Calculated bolt stresses accounting for RotaBolt hole**

	Operating loads	Accidental loads
Axial stress (MPa)	410	919
Nominal shear stress (MPa)	25	27

For Grade 10.9 bolts, the “yield” stress (0.2% proof stress) is specified as 900 MPa nominal and 940 MPa minimum, with tensile strength 1000 MPa nominal and 1040 MPa minimum. Comparing these with the values of Table 5-2,

- The calculated shear stresses in the bolts are low, at around 3% of tensile yield stress;
- Under operating loads,
  - Compared with yield, the calculated axial stress is around 44% of yield;
  - Compared with tensile strength, the calculated axial stress is around 39% of tensile strength;
- Under accidental loads,
  - Compared with yield, the calculated axial stress is around 98% of yield;
  - Compared with tensile strength, the calculated axial stress is around 88% of tensile strength;
- Given the low value of shear stress, tension will dominate.


FE results (see section 4.2) indicate that the actual bolt loads, accounting for pretensioning to 70% yield, will be changed from those given above; recalculating using the bolt loads from the FE analyses gives tensile loads and stresses as in Table 5-3.

**Table 5-3 Bolt loads from FE analyses and corresponding stresses**

	<b>Operating loads</b>	<b>Accidental loads</b>
Axial load (kN)	559	688
Axial stress (MPa)	710	874
Axial stress/ grade 10.9 yield	0.76	0.93
Axial stress/ grade 10.9 ultimate	0.68	0.84

## 5.2 Thread stripping check

In cases where engaged thread lengths are short, stripping of threads can occur. In the present arrangement, bolts will be inserted through the lower flange and engaged in threaded holes in the upper flange. A detail from the drawing of Kenz’s adaptor design is shown below in Figure 5-1.



**Figure 5-1 Detail of new secondary adaptor (see Figure 2-2)**

For M36 bolts, the thread shear area at the minor and major thread diameters may be calculated as

Minor diameter 30.654 mm

Major diameter 36.0 mm

Thickness of threaded flange 85 mm

Shear area in thread, fully engaged with flange

$$\text{Minor diameter} = \pi \cdot D \cdot t = 8185 \text{ mm}^2$$

$$\text{Major diameter} = \pi \cdot D \cdot t = 9613 \text{ mm}^2$$

On the minor diameter, shear failure of the thread would involve the bolt material. Here, for grade 10.9 bolt material, nominal yield stress = 900 MPa; taking shear yield as 0.577 of tensile yield, shear yield stress is approximately 519 MPa or 519 N/mm<sup>2</sup> so thread capacity is 8185 x 519 = 4,248,015 N or 4284 kN.

On the major diameter, shear failure of the thread would involve the flange material of the new secondary adaptor. The material here is Class 1b /8/ as shown in Figure 5-2. For S460N steel, the minimum yield at 85 mm thick is 400 MPa; taking shear yield as 0.577 of tensile yield, shear yield stress is approximately 230 MPa or 230 N/mm<sup>2</sup> so thread capacity is 9613 x 230 = 2,210,990 N or 2211 kN.

## DATA SHEET

### Material class specification

Class	yield MPa	Certificate EN 10204	Traceability level	Application
1	355	3.1 <sup>1</sup>	A/B	Special Z quality load path material; loaded in thickness direction
1a	690	3.1 <sup>1</sup>	A/B	Special Z quality load path material; loaded in thickness direction
1b	460	3.1 <sup>1</sup>	A/B	Special Z quality load path material; loaded in thickness direction
2	355	3.1	A/B	General load path material;
2a	690	3.1	A/B	General load path material; high strength steel
2b	460	3.1	A/B	General load path material; high strength steel
3	235	2.2	C	General non load path material; normal strength steel
4	650	3.1	A	General load path shafts and connection pins ( non welded )
5			C	Special non load path stainless steel material

Note <sup>1</sup> Forgings excluded. See applicable drawings and data sheets


**Figure 5-2 Kenz material classes/9/**

The bolt load under accidental loading is 722.3 kN (see Table 4-1) so with the thread fully engaged in the upper flange, accidental load is approximately 33% of thread capacity. At lower thread engagements the capacity will decrease in proportion; using this approach, the minimum thread engagement in the flange of the secondary adaptor to avoid thread stripping is 28.1 mm. The expected engagement is c 85 mm.

## 6 BOLTING FLANGE

### 6.1 Method of calculation

Stresses in the existing bolting flange were calculated, treating the flange as a cantilever beam as sketched in Figure 6-1. Since the number of bolts is large at 72, one bolt space covers only 5° so treating it as a simple cantilever under the maximum tensile bolt load is considered reasonable.



**Figure 6-1 Flange calculation**

From the geometry of the flange (see Figure 2-4), a lever arm of 61.7 mm may be calculated from the bolting pitch circle to the outer edge of the conical plate contact with the flange.

The flange section was taken as one bolt space wide at the outside of the supporting cone and with a thickness allowing for the maximum machining allowance of 3/16", i.e. 119.0 mm wide by 95.24 mm thick, giving a section modulus of  $179.89 \times 10^{-6} \text{ m}^3$ .

The flange material has properties as shown in Table 6-1 /14/.

**Table 6-1 Flange material properties /8/**

	<b>Yield stress (MPa)</b>	<b>UTS (MPa)</b>
Specified	315	490
Actual	346	480

## 6.2 Operating loads

To check stresses in the flange under operating loads, the maximum bolt loads listed above in section 4 were applied, i.e. 322 kN of axial load and 19.8 kN of shear load per bolt.

With the flange properties of the preceding section, this gave a bending moment of 19,866.5 Nm and a bending stress in the flange root of  $19,866.5 / 179.89 \times 10^{-6} / 10^6 \text{ MPa} = 110.4 \text{ MPa}$ .

The calculated stress is 35% of the specified flange material yield stress and 32% of the actual yield stress shown in the material mill certificate /14/.

## 6.3 Accidental loads

Under accidental loads, it was considered reasonable to permit yielding of the flange.

To check the flange strength under accidental loads, the bolt load was taken as the calculated failure load of a grade 10.9 M36 bolt, using the stress area and material tensile strength as in section 5, i.e. area 817 mm<sup>2</sup> and tensile strength 1040 MPa giving a failure load of 850 kN;


Using these values, the calculated flange stresses are summarised in Table 6-2.

**Table 6-2 Bolting flange: elastic stress calculation**

<b>Bolt failure load (kN)</b>	<b>Flange moment (Nm)</b>	<b>Flange elastic stress (MPa)</b>
850	52,445	292

Thus the calculated bolt failure load gives a moment within the actual elastic property of the flange. In practice some yielding may be expected local to the attachment to the pedestal, due to the local stress

concentration. Although not specifically designed to examine this detail, the finite element model described in section 4.2 indicated a local nodal averaged von Mises stress at the corner of 381 MPa under pretension + accidental load, or approximately 10% over yield. As can be seen from the plot below, this peak stress is a result of the local concentration. (Note that the high stresses at the ends of the bolt hole are a result of load transfer from the bolt.)



**Figure 6-2 Von Mises stresses (MPa) - pretension plus accidental load**

## 7 FATIGUE CHECKS

### 7.1 Fatigue in bolts

Fatigue lives for the bolts have been calculated based on the MIPEG crane history data provided for the BP and BD platforms/15//16/. This system records the lift history of the crane and includes figures for the lift weight and for the moment applied to the crane over a period of some 11 years. For structural fatigue, it has been assumed /15//16/ that the pattern of lifts with the new crane will be the same as the recorded history with the existing crane. The recorded history, adjusted for weight & CG data for the new crane, thus allows a lift pattern to be established for assessing future fatigue damage for crane operations.


In assessing the fatigue lives of the bolts, only damage from the new crane configuration was considered – new bolts will be installed with the new crane. The sequence of calculation was:

For each single recorded lift, using the new crane data,

- Calculate the maximum nominal load on an individual bolt position on the bolt circle, due to the crane moment;
- Interpolate to get the bolt load (see Figure 4-3)








**Figure 7-2 Location of node used for fatigue calculation**

The calculation approach was similar to that used for the bolts (see section 7.1) in that it was based on damage calculated for each MIPEG record to arrive at an annual damage rate, using the 'D' S-N curve. However, for the flange damage from the existing crane was taken into account. As with the bolt calculation, interpolation was used within the FE model results to take account of the nonlinearity of stresses with load due to flange separation (see Figure 7-3).



**Figure 7-3 Principal stress range vs applied external load**

Results of the calculation are shown in Table 7-2.

**Table 7-2      Calculated flange fatigue - old and new cranes**

Crane	Number of MIPEG records	Period covered by MIPEG records (years)	Old crane		Remaining capacity	New crane		
			Annual damage rate	Total damage, 35 years		Annual damage rate	Implied life (no DFF) (years)	Implied life (DFF=5) (years)
BP	18045	11.3	3.395E-04	1.188E-02	9.881E-01	2.221E-03	445	89
BD	34119	11.0	3.601E-04	1.260E-02	9.874E-01	4.060E-03	243	49

## 8 CONCLUSIONS

### 8.1 Strength

- Under operating loads,
  - the calculated axial bolt stress is around 44% of yield for grade 10.9 bolts, the FE analysis gave 76% yield including pretensioning;
  - the calculated axial bolt stress is around 39% of tensile strength for grade 10.9 bolts, the FE analysis showed 68% including pretensioning;
  - the calculated flange bending stress is 35% of the specified flange material yield stress and 32% of the actual yield stress shown in the material mill certificate /14/
- Under accidental loads,
  - the calculated axial bolt stress is around 98% of yield for grade 10.9 bolts, the FE analysis gave 93% yield including pretensioning;
  - the calculated bolt axial stress is around 88% of tensile strength for grade 10.9 bolts, the FE analysis gave 84% including pretensioning;
  - calculating bending of the flange under the failure load of an M36 grade 10.9 bolt indicates a bending stress of 292 MPa, below the specified 315 MPa yield stress of the flange material; in practice some local yielding is likely due to local concentration effects.

### 8.2 Fatigue

The projected life for the platform is until 2035, i.e. 18 years if crane replacement takes place in 2017.

The fatigue lives of bolts under the anticipated new crane loads appear adequate, well in excess of 18 years. The fatigue lives of the flanges have been calculated as a minimum of 49 years, taking into account a design fatigue factor (DFF) of 5, i.e. approximately 2.7 times the desired life.

## 9 REFERENCES

- /1/ DNV GL report, "Examination of crane adapter bolting and flange", DNV GL document number 10016304\90\04\001TN, Rev. 1, June 2016
- /2/ EN 13852-1:2013, Cranes, Offshore Cranes, Part 1: General-purpose offshore cranes
- /3/ Ruston-Bucyrus drawing 148557 Rev D, 14-01-1982
- /4/ Kenz Cranes document number 0310\_002 rev C, Installation number P337/P338, Centrica Storage: Rough 47/3B BD & BP Platform, 31-03-2016
- /5/ Kenz email forwarded by CSL 31-03-2016, DNV GL ref. 10016304\89\010i
- /6/ Lloyd's Register, "Code for Lifting Appliances in a Marine Environment", July 2016
- /7/ Email from B Roebuck, CSL to Nigel Sims, DNV GL: "Bolting information", 15-11-2016, DNV GL ref.10.016304\106\002i
- /8/ Email from B Roebuck, CSL to Nigel Sims, DNV GL: "RotaBolts - offshore use", 23-03-2017, DNV GL ref.10.016304\106\053i
- /9/ Kenz Cranes document number 0340\_001 rev C, Project no. P337N001, Centrica Storage: Structural Material Specification, 09-03-2016
- /10/ NS-EN 10025-3 January 2205: Table 5
- /11/ Email from B Roebuck, CSL to Wei Zhao, DNV GL: "C15062 - Crane Replacement Project - Minimum Failure Load of Client's Pedestal - Clarification Required", 03-03-2016, DNV GL ref.10.138332\04\920i
- /12/ Research Council on Structural Connections (RCSC), Specification for Structural Joints Using High-Strength Bolts, 2009
- /13/ Unbrako Engineering Guide – Socket Products, Unbrako Group, Deepak Fasteners Ltd
- /14/ Ruston Bucyrus mill certificate for flange: certificate no. 61955, supplied in pdf form of Data Dossier - MK100 Marine Crane - Serial No.39586-L6243 CD - 3 Volumes Part A - Ruston-Bucyrus - Rough 47-3B - Sheet 2 of 2.pdf by CSL, DNV GL ref. 10016304\89\014i.
- /15/ DNV GL report, "Rough BP Crane Pedestal Fatigue Analysis" DNV GL document number 10.138332.00\38\08\001R, Rev. 0 May 2016
- /16/ DNV GL report, "Rough BD East Crane Pedestal Fatigue Analysis" DNV GL document number 10.016304\82\08\001R, Rev. 0 June 2016
- /17/ DNV GL-RP-0005:2014-06, RP-C203 Fatigue Design of Offshore Steel Structures, 2014.